Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-09-12-35 **Date: 13/08/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Receipt : 08-08-19

ID : GF Roof Concrete

Type /Size : 150X150X150 mm

Grade/Age : M25 / 7 Days Compressive Strength

BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 13/08/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Roof Concrete	M25	06/08/2019	13/08/2019	149.66 X 149.33 X 151.77	22348	**8.569**	518.9	23.2	22.8
Roof Concrete	M25	06/08/2019	13/08/2019	149.65 X 151.17 X 149.39	22623	**8.902**	508.1	22.5	
Roof Concrete	M25	06/08/2019	13/08/2019	150.91 X 151.63 X 149.65	22882	**8.452**	520.6	22.7	

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 03/09/2019**

: Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Receipt : 08-08-19

ID : GF Roof Concrete

Type /Size : 150X150X150 mm

Grade/Age : M25 / 28 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 03/09/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
F Roof Concrete	M25	06/08/2019	03/09/2019	151.31 X 150.37 X 151.90	22754	**8.692**	624.7	27.5	
F Roof Concrete	M25	06/08/2019	03/09/2019	151.26 X 150.11 X 149.36	22707	**8.542**	596.5	26.3	27.5
F Roof Concrete	M25	06/08/2019	03/09/2019	151.13 X 150.83 X 150.55	22795	**8.525**	654.4	28.7	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 10/06/2019**

Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

r's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Receipt : 06-06-19

er ID : Chajja Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 7 Days Compressive Strength

ce to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

est : 10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Chajja Concrete	M20	03/06/2019	10/06/2019	151.57 X 150.18 X 150.10	22763	**8.139**	428.3	18.8	18.4
Chajja Concrete	M20	03/06/2019	10/06/2019	150.71 X 149.81 X 149.36	22578	**8.087**	406.7	18.0	
Chajja Concrete	M20	03/06/2019	10/06/2019	150.46 X 149.08 X 150.94	22429	**8.021**	409.4	18.3	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: CP-2019-09-12-35 **Date: 01/07/2019**

Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Receipt : 06-06-19

ID : Chajja Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 28 Days Compressive Strength

to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

est : 01/07/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Chajja Concrete	M20	03/06/2019	01/07/2019	151.46 X 150.85 X 149.49	22846	**8.244**	527.5	23.1	23.0
Chajja Concrete	M20	03/06/2019	01/07/2019	150.95 X 151.79 X 151.56	22912	**8.522**	514.9	22.5	
Chajja Concrete	M20	03/06/2019	01/07/2019	150.83 X 149.70 X 149.66	22579	**8.748**	528.5	23.4	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2019-09-12-35** **Date: 10/06/2019**

Name : Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.

: Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.

er's Reference : EE(Project)/Ynk Zone/WO/114/2017-18

Receipt : 06-06-19

er ID : Chajja Concrete

Type /Size : 150X150X150 mm

grade/Age : M20 / 7 Days Compressive Strength

ce to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Test : 10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Chajja Concrete	M20	03/06/2019	10/06/2019	151.62 X 151.12 X 151.80	22913	**8.139**	430.3	18.8	18.4
Chajja Concrete	M20	03/06/2019	10/06/2019	150.68 X 150.84 X 151.83	22729	**8.087**	421.0	18.5	
Chajja Concrete	M20	03/06/2019	10/06/2019	150.78 X 151.05 X 149.69	22775	**8.021**	410.5	18.0	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 01/07/2019

	:	**CP-2019-09-12-35**
t Name	:	Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.
	:	Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.
ner's Reference	:	EE(Project)/Ynk Zone/WO/114/2017-18
f Receipt	:	06-06-19
ner ID	:	Chajja Concrete
e Type /Size	:	150X150X150 mm
e grade/Age	:	M20 / 28 Days Compressive Strength
nce to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
f test	:	01/07/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Chajja Concrete	M20	03/06/2019	01/07/2019	151.73 X 151.60 X 151.68	23003	**8.244**	547.5	23.8	23.4
Chajja Concrete	M20	03/06/2019	01/07/2019	149.83 X 150.72 X 150.66	22582	**8.522**	508.2	22.5	
Chajja Concrete	M20	03/06/2019	01/07/2019	149.23 X 149.11 X 152.00	22251	**8.748**	533.4	24.0	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 10/06/2019

D	:	**CP-2019-09-12-35**
t Name	:	Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.
y	:	Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.
ner's Reference	:	EE(Project)/Ynk Zone/WO/114/2017-18
Receipt	:	06-06-19
ner ID	:	Chajja Concrete
Type /Size	:	150X150X150 mm
grade/Age	:	M20 / 7 Days Compressive Strength
ce to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Test	:	10/06/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Chajja Concrete	M20	03/06/2019	10/06/2019	151.63 X 149.26 X 151.87	22631	**8.139**	420.6	18.6	18.6
Chajja Concrete	M20	03/06/2019	10/06/2019	149.20 X 151.11 X 151.06	22545	**8.087**	418.8	18.6	
Chajja Concrete	M20	03/06/2019	10/06/2019	149.80 X 151.87 X 151.69	22749	**8.021**	424.5	18.7	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 01/07/2019

D	:	**CP-2019-09-12-35**
t Name	:	Construction of Indoor Stadium With All Amenities at Sahakarnagar in Ward No.08 Kodigehalli, Kodigehalli Sub Division.
y	:	Sri.Abbu Sambasiva Reddy # 1-B-3, Sree Arcade Layout 4th Block, DB Sandra, Vidyaranyapura, Bangalore-560097.
mer's Reference	:	EE(Project)/Ynk Zone/WO/114/2017-18
f Receipt	:	06-06-19
mer ID	:	Chajja Concrete
e Type /Size	:	150X150X150 mm
e grade/Age	:	M20 / 28 Days Compressive Strength
nce to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
f test	:	01/07/2019

Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
Chajja Concrete	M20	03/06/2019	01/07/2019	152.00 X 151.52 X 150.80	23030	**8.244**	531.6	23.1	22.9
Chajja Concrete	M20	03/06/2019	01/07/2019	152.00 X 150.45 X 149.14	22868	**8.522**	510.5	22.3	
Chajja Concrete	M20	03/06/2019	01/07/2019	150.87 X 149.03 X 151.53	22485	**8.748**	523.0	23.3	

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****